CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No.　　　3240-1521:120　　　　　　　　　　　　　　　　　　Page 1 of 1

CATEGORY:　　　Duct Smoke Detector Housings/Bases

LISTEE:　　　Siemens Building Technologies, Inc., 1000 Deerfield Parkway, Buffalo Grove, IL 60089
　　　　　　　Contact: Ferd Orpano (847) 941-6176 FAX (866) 699-0238

DESIGN:　　　Model SIGA-DH-LG and *6260A-CU Duct Smoke Detector Units.　Units consist of a metal
　　　　　　enclosure, relay, electrical components, a separately listed open area detector, a detector
　　　　　　base and a sampling and exhaust tube.　Refer to listee's data sheet for additional detailed
　　　　　　product description and operational considerations.

RATING:　　　300-4000 fpm

INSTALLATION:　　In accordance with listee's printed installation instructions, applicable codes and ordinances
　　　　　　and in a manner acceptable to the authority having jurisdiction.

MARKING:　　　Listee's name, model number, rating, and UL label.

APPROVAL:　　　Listed as duct smoke detector housing units for use with separately listed compatible control
　　　　　　units.　Model SIGA-DH-LG with Models SIGA-IPHS or SIGA-IPHS-LG detector head (CSFM
　　　　　　Listing No. 7558-1521:107), the sensitivity must be set at Levels 1 through 4 for velocities
　　　　　　over 1000 fpm. Refer to listee's Installation Instruction Manual for details.

NOTE:　　　Formerly 3240-1469:120

XLF:　　　3240-1591:108

*Rev. 03-16-04

Date Issued:　　**MARCH 16, 2004**　　　　　　*Listing Expires* **June 30, 2004**

A*uthorized By:*　　**DIANE K. AREND**, *Senior Deputy*
　　　　　　Program Manager